



S.G. ADAPT.



OUTAGE & FILL CPLNG.'S



VAPOR CPLNG.



RELIEF CPLNG.

SYM	DATE	BY	REVISION	APP	XREF REV.	NOTES
C		CH		JR		
D		RB		JC		
				EGB		

SPECIFICATIONS	
O.D. 12&12 LGTH. 48&60	SH.
MAWP 312 PSI @ 650 °F	HD.
RT- MDMT -20 °F@ 312 PSI	GAL. 49.1 S.A. 29.2
EXMT TEST PSI	WT. 183# CU.FT. 6.6
XRAY W	CORR ALW SH HD
CRN D9354.512346780	CODE ASME UW-11(a)(5)(b)
	PER DATE OF DWG/LAST REV
WELD DETAILS: M-1932	
STD. TOLERANCES (UNLESS OTHERWISE NOTED): M-2461	

q:\2000\

MANCHESTER TANK

MOTORFUEL TANK
REMOTE FILL

DRAWN BY:	DATE	SCALE:
PRW		NONE
APPR. BY:	DATE	DRWG NO.
AS		211447