


SYM	DATE	BY	REVISION	APP	NOTES
1		KAT		BS	

SPECIFICATION	
O.D. 10&12 LGTH. 30	SH. HD.
MAMP 312 PSI @ 650 °F	GAL. 22.4 SA 15.2
RT- MDMT -20 °F @ 312 PSI	WT. 11.3# CU.FT. 3.0
EXMT TEST W	CORR ALW SH HD
XRAY	CODE ASME SECT. VIII, DIV. 1
CRN M4492.5134678907N; V873.2	PER DATE OF DWG/FAST REV
WELD DETAILS: M-1932	STD. TOLERANCES (UNLESS OTHERWISE NOTED): M-2461



MOTORFUEL TANK
REMOTE FILL

Q:\2000\

DRAWN BY: JR	DATE:	SCALE: NONE
APPR. BY: JR	DATE:	DRWG NO. 270155